

APPENDIX J

EXISTING PRV SETPOINTS

City of Richland

PRV CHECK LIST

Location & Size	Date	High	Low	Range	Comments	Initials
Hills Mobile Home Park 3" & 8" High 45 Low 40	9/29/2014	46	42	15 - 75		
The "Y" 3" & 10" High 80 Low 74	9/16/2014	80	75	30 - 300		
Meadow Hills 3" & 6" High 80 Low 75	9/4/2014	80	75	30 - 300	new seat & diaphragm in 3"	
136 Newhaven 3" & 6" High 60 Low 55	9/29/2014	56	47	30 - 300		
307 Riverwood 3" & 6" High 65 Low 55	9/29/2014	50	45	30 - 300		
1134 Englewood 3" & 6" High 60 Low 50	10/02//20 14	50	46	30 - 300		
Engelwood & Viewmoor 3" & 6" High 60 Low 50	9/30/2014	45	35	30 - 300		
1119 Oxford 3" & 6" High 60 Low 50	9/30/2014	47	40	30 - 300		
Edgewood 3" & 6" 60 & 50	10/2/2014	45	40	30 - 300		
High Meadows 3" & 8" High 60 Low 50	9/29/2014	50	47	30 - 300		
1130 Hills West Way 3" & 6" High 60 Low 50	10/2/2014	47	37	30 - 300		
Meadow Hills High Point 2" & 6" High 14 Low 10	9/30/2014	18	16	2 - 30	new gauge	
136 Orchard Way 3" & 6"	not in service					

Dallas & White Bluffs 3" & 6" High 50 Low 45	10/2/2014	50	40			
Dallas Rd 3" & 8" High 65 Low 60	10/1/2014	65	60		new gauges	

PRV CHECK LIST

Location & Size	Date	High	Low	Range	Comments	Initials
West Vineyard 3" & 6" High 42 Low 37	10/1/2014	42	37			
Badger S Pump Station Surge Valve 4" High 210 Low 150	10/3/2014	110	225			

PRESSURE RELIEF CHECK LIST

Location & Size	Date	Setting	Opens At	Status	Comments	Initials
UV Facility Pressure Relief	10/3/2014	80	85			
Meadow Hills PS Pressure Relief	10/3/2014	220	225			
Keene Rd. PS Pressure Relief	10/3/2014	135	135			
Badger Mtn PS Surge Valve	10/6/2014	110	85		fuse holder is bad	
Westcliffe PS Pressure Relief	10/3/2014	90	100			
Horn Rapids PS Pressure Relief	10/6/2014	115	106			
WTP - West Side Pressure Relief	10/3/2014	105	110			

CITY OF RICHLAND

WTP - East Side Pressure Relief	10/3/2014	105	110			
WTP - Cla-Val #7 Effluent Pressure Relief	10/3/2014	115	115			
WTP Pump 1 & 2 Pump Pit Surge Valve	7/25/2013	110	116			
H. R. Fire Booster Station Pressure Relief	10/6/2014	115	105			
Badger MTN PS #2	10/6/2014	65	65			

Interties

Location	Date	Opens At	Closes At	Status	Comments	Initials
Tapteal/Columbia Center Blvd			Upstream 90 Downstream 60			
Kennewick/Richland at Gage & Steptoe						
West Richland						
Tri-City Estates						
Kennewick Irrigation District					PRV - downstream 75 - 80 psi	
Badger Mountain Irrigation District						