



# Addressing

## Standard

- International Fire Code 2003 – 505.1

## Practice

- Exterior address numbers shall be a minimum of 4 inches in height with a ½ inch stroke, visible from the road, and of a contrasting color.
- Interior address numbers shall be a minimum of 1-½ inches high and of a contrasting color.
- Approved address numbers shall be placed on all new and remodeled buildings, including one and two family dwellings, in such a position as to be plainly visible and legible from the road or street fronting the property.
- When a building or complex is not visible, or too far, from the road or street, provisions shall be made to clearly identify which driveway or roadway serves the addresses or range of addresses. An address reader board or monument at the entrance to the complex may be required.
- Access doors of individual dwelling units and commercial tenant spaces shall be clearly marked.
- The City of Richland Planning Department assigns all addresses.