



Elevators

Standard

Richland Municipal Code Title 20 Chapter 20.09

Practice

This standard shall be applied to new passenger elevators in every occupancy

- All passenger elevators shall have a minimum interior dimension of 80" in width and 51" in depth.
- The minimum door opening width shall be 42".

Exceptions:

- R3 occupancies
- Occupancies with exterior access to an approved walkway for all floors served by the elevator

Guide

This development standard is written to facilitate the rapid response of emergency medical personnel and the use of an ambulance gurney in elevators. A side-opening door is preferable to a center-opening door.