



Tegris Entry Requirements

Standard

Washington State most currently adopted version of the International Fire Code & RMC Title 20

Practice

The purpose of this standard is to provide the requirements for data entry of fixed fire safety systems into Tegrifire.com.

- Fixed fire protection system testing records, noted throughout the International Fire Code and referenced standards, shall be submitted to Richland Fire & Emergency Services in the manner and frequency determined by the fire code official, as set forth in RMC Title 20.02.080. Currently Tegrifire.com.
- It is the responsibility of the fire code official to set up basic occupancy information within Tegrifire.com. Fixed fire protection systems, system changes, updates, and initial/continuing inspection data entry is the responsibility of the installation and testing company as approved by the fire code official.
- Tenant improvement plans submitted through the building department will not be approved by the Fire Marshal's office until all testing and data entry is current within Tegrifire.com.
- An initial inspection report is required to be submitted to the Fire Marshal's Office via www.Tegrifire.com to begin the annual inspection cycle, prior to an acceptance testing permit being requested or scheduled through "buildingdepartment.com". System acceptance tests that are requested through "buildingdepartment.com" will not be scheduled without the life safety system and its initial inspection information being input first.
- Installation, testing, and maintenance information will be entered into Tegrifire.com by the contractor within 7 business days of completion.

Guide

Modifications of this standard may be made with the approval of the Chief or designee.
2 August 2019